BILL NO. S-88-01-30

SPECIAL ORDINANCE NO. S-25-88

AN ORDINANCE approving the awarding of Reference # 829 by the City of Fort Wayne, Indiana, by and through its Department of Purchasing and the Water Products Company, for the Water Maintenance and Service Department.

NOW, THEREFORE, BE IT ORDAINED BY THE COMMON COUNCIL OF THE CITY OF FORT WAYNE, INDIANA:

SECTION 1. That Reference #829 between the City of Fort Wayne, by and through its Department of Purchasing and the Water Products Company, for the Water Maintenance and Service Department, respectfully for:

the purchase of the 1988 requirements for Fire Hydrants for the City of Fort Wayne;

involving a total cost of Thirty-Six Thousand, Three Hundred and 00/100 ($36,300.00), all as more particularly set forth in said Reference #829 which is on file in the Office of the Department Purchasing, and is by reference incorporated herein, made a part hereof, and is hereby in all things ratified, confirmed and approved.

SECTION 2. That this Ordinance shall be in full force and effect from and after its passage and any and all necessary approval by the Mayor.

Councilmember

APPROVED AS TO FORM
AND LEGALITY

J. Timothy McCaulay, City Attorney

REFERENCE #829
11/24/87

FIRE HYDRANTS
WMS

| | TREATY | WATER PROD | UNDERGROUND |
|---|---|---|---|
| BRAND/MODEL | MUELLER A-423 | AM DARLING | CLOW F2500<br>KENNEDY K-81A |
| COST FOR EACH | $490.00 | $484.00 | $491.85 |
| TOTAL COST | $36,750.00 | $36,300.00 | $36,888.75 |
| DEL TIME | 3-4 WEEKS | 7-14 DAYS | 4 WEEKS |
| FOB | FTW | FTW | FTW |

*WE RESERVE THE RIGHT TO TO FURNISH EITHER, OR SOME OF BOTH

2.
(Front Page)

CITY OF FORT WAYNE

DEPARTMENT OF PURCHASING
ONE MAIN STREET - ROOM 350
FORT WAYNE, INDIANA 46802

BID REFERENCE # 829

DATE November 9, 1987

DUE DATE Tuesday, November 24, 1987 at 11:00 A.M.

Department receiving bid items Water Maintenance & Service
415 E. Wallace Street
Fort Wayne, IN 46803

Bid Bond Required NO ____ YES X AMOUNT 5%

Performance Bond Required NO X YES ____ AMOUNT ____

Affirmative Action -On file with the City of Fort Wayne ✓
- Attached to this document ____

Prompt payment discounts will be allowed as follows: 0 % if paid within Net 30 days.

The City of Fort Wayne is exempt from Federal excise and Indiana State Sale Tax. The City's Indiana Sales Tax Exemption Certificate number is 356-001-255 0013, prices should not include these taxes.

The execution hereof by the bidder is acceptance of all terms and conditions herein and in that regard the bidder agrees to be bound by same and be bound to the amount of his/her bid for a period of ninety (90) days.

Underwood Pipe & Valve Inc
Name of Company

by James P Butler Agent
(signature)

Address 617 Ley Rd

City Ft Wayne, Ind

FORT WAYNE WHERE AMERICA WORKS

# SPECIFICATIONS FOR FIRE HYDRANTS

Fire Hydrants used in the construction of water mains, and replacements thereof, shall be made in accordance with the latest revision of the American Water Works Association Standard, designated C502.

Fire Hydrants shall be constructed such that the main valve closes with the line pressure, and shall open by turning left (counterclockwise). The main valve opening shall be a minimum of five (5) inches and its assembly, including the drain valve assembly, shall be removable through the upper barrel without removing the nozzle section. The main valve seat-ring shall thread into a bronze insert located in the shoe of the hydrant or thread into a bronze drain ring located between the lower barrel and shoe of the hydrant. All bronze or brass parts, in constant contact with water, and all flow characteristics of hydrants offered and supplied shall meet or exceed the requirements of Standard C502.

All Fire Hydrant parts, such as lower barrel, shoe and flanges, shall be constructied in accordance with the latest revisions of Paragraph 3.1 of AWWA Standard C502. The ground line flange is to be located not more than six (6) inches above the finished grade mark of the hydrant for a standard 5-1/2' bury.

The connection between the upper and lower barrels of fire hydrants shall be in the form of a traffic safety device that will allow rotation of the upper barrel in any increment from 1 to 180 degrees, in either direction, without disassembly. The hydrant shall be extendable without removing lower barrel. The upper and lower stem shall be joined by a traffic safety stem-coupling which, along with the connection between the upper and lower barrels, will break on traffic impact.

The bonnet or top section shall be equipped with a lubricant reservoir or chamber designed such that the operating threads of the stem will, at all times, be totally enclosed. The operating nut shall have a weather shield cast integrally with it or an o-ring seal shall be incorporated in the hydrant cover or top. All pressure seals shall be rubber o-rings.

Fire Hydrants shall be equipped with a 1-1/2 inch pentagon operating nut and hose nozzle cap removal device; supplied without nozzle cap chains; one - 4-1/2 inch pumper and two - 2-1/2 inch hose nozzles, all on the same plane, and having National Standard Fire hose threads of four (4) and seven and one-half (7-1/2) threads per inch, respectively, and shall be threaded to screw into the nozzle section and be securely fastened to prevent rotation; they shall be painted Federal Yellow; the shoe connection for attachment to the water main shall be six (6) inch mechanical joint, complete with accessories, including lead-tipped rubber gaskets and set-screw retainer glands, designed to fit both centrifugal and sand cast pipe.

The following fire hydrants, or approved equals, are the only fire hydrants which will be accepted for use in connection with water main installation:

| BRAND NAME | CATALOG NO. |
|---|---|
| CLOW | F-2500 |
| KENNEDY | K-81A |
| MUELLER | A-423 |

COST FOR EACH 5-1/2' BURY FIRE HYDRANT $ 491.85 ea

(EST. QTY OF 75 UNITS TOTAL) $ 36,888.75

STATE BRAND AND MODEL NUMBER Clow F2500 OR Kenney K-81A
We Reserve The Right To Furnish Either, OR Some of Both

DELIVERY TIME A.R.O. 4 WEEKS

F.O.B. PT WAYNE, IND

2.
(Front Page)

CITY OF FORT WAYNE

DEPARTMENT OF PURCHASING
ONE MAIN STREET - ROOM 350
FORT WAYNE, INDIANA 46802

BID REFERENCE # 829

DATE November 9, 1987

DUE DATE Tuesday, November 24, 1987 at 11:00 A.M.

Department receiving bid items Water Maintenance & Service
415 E. Wallace Street
Fort Wayne, IN 46803

Bid Bond Required NO ____ YES X AMOUNT 5%

Performance Bond Required NO X YES ____ AMOUNT ____

Affirmative Action -On file with the City of Fort Wayne X
- Attached to this document ____

Prompt payment discounts will be allowed as follows: Net %
if paid within 30 days.

The City of Fort Wayne is exempt from Federal excise and Indiana State Sale Tax. The City's Indiana Sales Tax Exemption Certificate number is 356-001-255 0013, prices should not include these taxes.

The execution hereof by the bidder is acceptance of all terms and conditions herein and in that regard the bidder agrees to be bound by same and be bound to the amount of his/her bid for a period of ninety (90) days.

Water Products Company
Name of Company

by Tony Titus Agent
(signature)

Address 112 W. Water St. P.O. Box 55

City Wabash, Indiana 46992

FORT WAYNE WHERE AMERICA WORKS

# SPECIFICATIONS FOR FIRE HYDRANTS

Fire Hydrants used in the construction of water mains, and replacements thereof, shall be made in accordance with the latest revision of the American Water Works Association Standard, designated C502.

Fire Hydrants shall be constructed such that the main valve closes with the line pressure, and shall open by turning left (counterclockwise). The main valve opening shall be a minimum of five (5) inches and its assembly, including the drain valve assembly, shall be removable through the upper barrel without removing the nozzle section. The main valve seat-ring shall thread into a bronze insert located in the shoe of the hydrant or thread into a bronze drain ring located between the lower barrel and shoe of the hydrant. All bronze or brass parts, in constant contact with water, and all flow characteristics of hydrants offered and supplied shall meet or exceed the requirements of Standard C502.

All Fire Hydrant parts, such as lower barrel, shoe and flanges, shall be constructied in accordance with the latest revisions of Paragraph 3.1 of AWWA Standard C502. The ground line flange is to be located not more than six (6) inches above the finished grade mark of the hydrant for a standard 5-1/2' bury.

The connection between the upper and lower barrels of fire hydrants shall be in the form of a traffic safety device that will allow rotation of the upper barrel in any increment from 1 to 180 degrees, in either direction, without disassembly. The hydrant shall be extendable without removing lower barrel. The upper and lower stem shall be joined by a traffic safety stem-coupling which, along with the connection between the upper and lower barrels, will break on traffic impact.

The bonnet or top section shall be equipped with a lubricant reservoir or chamber designed such that the operating threads of the stem will, at all times, be totally enclosed. The operating nut shall have a weather shield cast integrally with it or an o-ring seal shall be incorporated in the hydrant cover or top. All pressure seals shall be rubber o-rings.

Fire Hydrants shall be equipped with a 1-1/2 inch pentagon operating nut and hose nozzle cap removal device; supplied without nozzle cap chains; one - 4-1/2 inch pumper and two - 2-1/2 inch hose nozzles, all on the same plane, and having National Standard Fire hose threads of four (4) and seven and one-half (7-1/2) threads per inch, respectively, and shall be threaded to screw into the nozzle section and be securely fastened to prevent rotation; they shall be painted Federal Yellow; the shoe connection for attachment to the water main shall be six (6) inch mechanical joint, complete with accessories, including lead-tipped rubber gaskets and set-screw retainer glands, designed to fit both centrifugal and sand cast pipe.

The following fire hydrants, or approved equals, are the only fire hydrants which will be accepted for use in connection with water main installation:

| BRAND NAME | CATALOG NO. |
|---|---|
| American Darling | B-62-B |
| CLOW | F-2500 |
| KENNEDY | K-81A |
| MUELLER | A-423 |

COST FOR EACH 5-1/2' BURY FIRE HYDRANT $ 484.00

(EST. QTY OF 75 UNITS TOTAL) $ 36,300.00

STATE BRAND AND MODEL NUMBER American Darling B-62-B

DELIVERY TIME A.R.O. 7-14 Days

F.O.B. Fort Wayne, Indiana

2.
(Front Page)

CITY OF FORT WAYNE

DEPARTMENT OF PURCHASING
ONE MAIN STREET - ROOM 350
FORT WAYNE, INDIANA 46802

BID REFERENCE # 829

DATE November 9, 1987

DUE DATE Tuesday, November 24, 1987 at 11:00 A.M.

Department receiving bid items Water Maintenance & Service
415 E. Wallace Street
Fort Wayne, IN 46803

Bid Bond Required NO ____ YES X AMOUNT 5%

Performance Bond Required NO X YES ____ AMOUNT ____

Affirmative Action -On file with the City of Fort Wayne ____
- Attached to this document X

Prompt payment discounts will be allowed as follows: N/A %
if paid within N/A days. NET 30 DAYS

The City of Fort Wayne is exempt from Federal excise and Indiana State Sale Tax. The City's Indiana Sales Tax Exemption Certificate number is 356-001-255 0013, prices should not include these taxes.

The execution hereof by the bidder is acceptance of all terms and conditions herein and in that regard the bidder agrees to be bound by same and be bound to the amount of his/her bid for a period of ninety (90) days.

THE TREATY COMPANY
Name of Company

by A. C. McElwain Agent
(signature)

Address 501 Gray Ave., P.O. Box 40

City Greenville, OH 45331

FORT WAYNE WHERE AMERICA WORKS

# SPECIFICATIONS FOR FIRE HYDRANTS

Fire Hydrants used in the construction of water mains, and replacements thereof, shall be made in accordance with the latest revision of the American Water Works Association Standard, designated C502.

Fire Hydrants shall be constructed such that the main valve closes with the line pressure, and shall open by turning left (counterclockwise). The main valve opening shall be a minimum of five (5) inches and its assembly, including the drain valve assembly, shall be removable through the upper barrel without removing the nozzle section. The main valve seat-ring shall thread into a bronze insert located in the shoe of the hydrant or thread into a bronze drain ring located between the lower barrel and shoe of the hydrant. All bronze or brass parts, in constant contact with water, and all flow characteristics of hydrants offered and supplied shall meet or exceed the requirements of Standard C502.

All Fire Hydrant parts, such as lower barrel, shoe and flanges, shall be constructied in accordance with the latest revisions of Paragraph 3.1 of AWWA Standard C502. The ground line flange is to be located not more than six (6) inches above the finished grade mark of the hydrant for a standard 5-1/2' bury.

The connection between the upper and lower barrels of fire hydrants shall be in the form of a traffic safety device that will allow rotation of the upper barrel in any increment from 1 to 180 degrees, in either direction, without disassembly. The hydrant shall be extendable without removing lower barrel. The upper and lower stem shall be joined by a traffic safety stem-coupling which, along with the connection between the upper and lower barrels, will break on traffic impact.

The bonnet or top section shall be equipped with a lubricant reservoir or chamber designed such that the operating threads of the stem will, at all times, be totally enclosed. The operating nut shall have a weather shield cast integrally with it or an o-ring seal shall be incorporated in the hydrant cover or top. All pressure seals shall be rubber o-rings.

Fire Hydrants shall be equipped with a 1-1/2 inch pentagon operating nut and hose nozzle cap removal device; supplied without nozzle cap chains; one - 4-1/2 inch pumper and two - 2-1/2 inch hose nozzles, all on the same plane, and having National Standard Fire hose threads of four (4) and seven and one-half (7-1/2) threads per inch, respectively, and shall be threaded to screw into the nozzle section and be securely fastened to prevent rotation; they shall be painted Federal Yellow; the shoe connection for attachment to the water main shall be six (6) inch mechanical joint, complete with accessories, including lead-tipped rubber gaskets and set-screw retainer glands, designed to fit both centrifugal and sand cast pipe.

The following fire hydrants, or approved equals, are the only fire hydrants which will be accepted for use in connection with water main installation:

| BRAND NAME | CATALOG NO. |
|---|---|
| CLOW | F-2500 |
| KENNEDY | K-81A |
| MUELLER | A-423 |

COST FOR EACH 5-1/2' BURY FIRE HYDRANT $ 490.00

(EST. QTY OF 75 UNITS TOTAL) $ 36,750.00

STATE BRAND AND MODEL NUMBER Mueller A-423

DELIVERY TIME A.R.O. 3 to 4 Weeks

F.O.B. Destination

Read the first time in full and on motion by Burns, seconded by Talarico, and duly adopted, read the second time by title and referred to the Committee on City Utilities (and the City Plan Commission for recommendation) and Public Hearing to be held after due legal notice, at the Council Conference Room 128, City-County Building, Fort Wayne, Indiana, on _____, the _____, day of _____, 19____, at _____ o'clock ____.M.,E.S.T.

DATED: 1-26-88

Sandra E. Kennedy
SANDRA E. KENNEDY, CITY CLERK

Read the third time in full and on motion by Burns, seconded by Talarico, and duly adopted, placed on its passage. PASSED ~~LOST~~ by the following vote:

| | AYES | NAYS | ABSTAINED | ABSENT |
|---|---|---|---|---|
| TOTAL VOTES | 9 | | | |
| BRADBURY | ✓ | | | |
| BURNS | ✓ | | | |
| GiaQUINTA | ✓ | | | |
| HENRY | ✓ | | | |
| LONG | ✓ | | | |
| REDD | ✓ | | | |
| SCHMIDT | ✓ | | | |
| STIER | ✓ | | | |
| TALARICO | ✓ | | | |

DATED: 2-9-88

Sandra E. Kennedy
SANDRA E. KENNEDY, CITY CLERK

Passed and adopted by the Common Council of the City of Fort Wayne, Indiana, as ~~(ANNEXATION)~~ ~~(APPROPRIATION)~~ (GENERAL) (SPECIAL) (ZONING MAP) ORDINANCE RESOLUTION NO. R-25-88 on the 9th day of February, 19 88,

ATTEST: Sandra E. Kennedy
SANDRA E. KENNEDY, CITY CLERK

SEAL

Thomas C. Henry
PRESIDING OFFICER

Presented by me to the Mayor of the City of Fort Wayne, Indiana, on the 10th day of February, 19 88, at the hour of 11:30 o'clock A.M.,E.S.T.

Sandra E. Kennedy
SANDRA E. KENNEDY, CITY CLERK

Approved and signed by me this 10th day of February, 19 88, at the hour of 11:35 o'clock A.M.,E.S.T.

P. Helmke
PAUL HELMKE, MAYOR

DIGEST SHEET

TITLE OF ORDINANCE: SPECIAL

DEPARTMENT REQUESTING ORDINANCE: PURCHASING

SYNOPSIS OF ORDINANCE:

S-88-01-30

An ordinance approving the award of Reference #829 with respect to the purchase of the 1988 requirements for Fire Hydrants for the City of Fort Wayne. Through the specifications in that reference for the Water Maintenance & Service Department. Prior approval was requested and received on January 12, 1988.

EFFECT OF PASSAGE:

The City will have the needed supplies for the installation of, and repair of, fire hydrants when it is needed.

EFFECT OF NON-PASSAGE:

The department would not have the supplies to replace, install, or repair fire hydrants as they are required.

MONEY INVOLVED (Direct costs, Expenditures, Savings):

Water Products Company $36,300.00+/-

ASSIGNED TO COMMITTEE (President):

BILL NO. S-88-01-30

REPORT OF THE COMMITTEE ON CITY UTILITIES

WE, YOUR COMMITTEE ON CITY UTILITIES TO WHOM WAS REFERRED AN (ORDINANCE) ~~(RESOLUTION)~~ approving the awarding of Reference #829by the City of Fort Wayne, Indiana, by and through its Department of Purchasing and the Water Products Company, for the Water Maintenance and Service Department

HAVE HAD SAID (ORDINANCE) ~~(RESOLUTION)~~ UNDER CONSIDERATION AND BEG LEAVE TO REPORT BACK TO THE COMMON COUNCIL THAT SAID (ORDINANCE) ~~(RESOLUTION)~~

| YES | | NO |
|---|---|---|
| | PAUL M. BURNS<br>CHAIRMAN | |
| | CHARLES B. REDD<br>VICE CHAIRMAN | |
| | MARK E. GiaQUINTA | |
| | SAMUEL J. TALARICO | |
| | JAMES S. STIER | |

CONCURRED IN 2-9-88

Sandra E. Kennedy

Sandra E. Kennedy
City Clerk